



TRI NUCLEAR CORP.

THE INDUSTRY STANDARD IN UNDERWATER FILTRATION

WWW.TRINUCLEAR.COM -- P.O. BOX 1130 BALLSTON LAKE, NY 12019 -- TEL: 518-399-1389 -- FAX:518-399-9586

UD-48A Underwater Demineralizer

Tri Nuclear has developed a large stand-alone Underwater Demineralizer which is ideal for processing large amounts of water rapidly.

Tri Nuclear's Underwater Demineralizers can be operated for long periods practically unattended without the need for maintenance or resin change out, all while controlling water chemistry and reducing pool water activity.

Because the portable Underwater Demineralizer is submerged, it needs no external shielding, or hoses running in or out of the water that may cause rippling, poor visibility or personnel contamination.

Tri Nuclear's Underwater Demineralizer operate under negative pressure which allows the pump to be gravity seated and does not require any special tooling to install or remove the pump underwater.

Features:

- Rapid system deployment via camlock hose connections, twist lock electrical connections, and Phase Reversing control boxes
- Customer supplied resin for best results via proper selection
- Underwater service requiring no additional shielding
- Remote resin sluice and charge
- Lifting Certified per NUREG0612

Specifications:

- | | |
|---------------------------|------------|
| • System Flow Rate: | 200 GPM |
| • Resin Capacity: | 50 Cu. Ft. |
| • Diameter: | 48 in. |
| • System Height: | 100 in. |
| • Vessel Height: | 76-1/2 in. |
| • Pump Weight: | 85 lbs. |
| • Vessel Empty with Pump: | 1,275 lbs. |
| • Vessel Full with Pump: | 5,750 lbs. |



UD-48A Vessel with Pump

Operational Details:

The UD-48A system has two different system configurations identified by the method the system circulates water.

In the discharge hose mode, unfiltered water from the pool enters the top of the vessel travels through the media bed, and is discharged away from the vessel back to the pool via the pump, discharge hose and diffuser.

In the suction hose mode, unfiltered water from the pool enters the suction hose via suction strainer, travels down the length of suction hose toward the vessel, travels through the media bed, and is discharged at the top of the vessel back to the pool via the pump.